

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-1130:202 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Honeywell Inc., 1500 West Dundee Road, Arlington Heights, IL 60004
Contact: Bob Hodgson (847) 797-4403

DESIGN: Models XLS-LSRA and XLS-LSRA-C annunciators. Refer to listee's data sheet for additional detailed product description and operational consideration.

RATING: 18.4 - 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as annunciators for use with separately listed compatible fire alarm control units.

XLF: 7120-1388:221

03-01-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 13, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager